1.0	machine connection: drain connection hose, DN 22 hose fitted as odour trap in interior of machine						
1.1	drain (max. 540 mm above finished floor level), DN 50						
2.0	Machine connection: fresh water supply, G 3/4"						
2.2	Soft cold water 10°C, DN 15, G 3/4 a						
	max. 0,54 mmol/l CaCO₃ (max. 3°dH)						
	Flow rate: min. 8 l/min						
	electrical conductibility 70 - 1000 μS/cm						
	Minimum flow pressure: 100 kPa / 1.0 bar in front of solenoid valve						
	Maximum pressure: 500 kPa / 5.0 bar in front of pressure reducer						
	stopcock and fine screen ≤ 25 µm						
3.0	Machine connection: electrical connection cable 5G 2,5mm ²						
3.1	electricity supply to the machine: 3N PE 400V ~ 50Hz						
	nominal current / - capacity: 15.7 A / 6.9 kW						
	Fuse protection: 16 A						
	∀ Voltage equalising cable						
	The master switch must be provided on site						
	Note: Electrical equipment suitable for supply voltage:						
	3N PE 380-415 V 50 Hz / 1N PE 220-240 V 50 Hz						
6.0	Heat load of warewash area						
6.1	for 20 programme cycles/h						
	total 2.1 kW, perceptible 1.4 kW, latent 0.7 kW						
all cables, pipes etc leaving machine 1,6 m							
the position of the connection piping can also be mirror-inverted!							
Machine Equipment							

Machine Equipment

(A) Entry height


Final rinse dosing unit with suction lance (blue connector)

Detergent dosing unit and suction lance

GiO MODULE (plinth, 120 mm) M2

Roller base 35 mm

Please observe the installation indications of the additional document MP_T-INFO-GIO_M2_M-iClean-U_EN.pdf





MEIKO Australia-Pacific Pty Ltd Unit 4, 72 - 74 Gibbes Street Chatswood NSW 2067 TEL. +61-1300 367 730, Telefax +61-1300 656 420 E-MAIL: info@meiko.com.au

This drawing may not be neither passed to third parties for their information or copied or used for competitive purposes without our consent. All rights reserved. We reserve the right to make changes resulting from technical progress. This drawing was computer generated and is not subject to the checking and any release process; it is also not subject to change management.

This document is only valid in conjunction with the conditions defined in Supplementary Sheet "Important Information". These can be requested from the manufacturer or downloaded from the Partnernet.

	Revision						
)	Reference DISHV STANI			WING / AUS			
_					GIO MODULE PLINTH		
d	TYPE:	GL	ASSES				
	Drawing-No).			Order-No.		
	S0008	613	2				
	Scale	drav	vn:		checked:		
	1:25	03.	08.2020	m-iplan	03.08.2020 m-iplan		

MP000429623.2.5

ΕN